

CERTIFICATE OF COMPLIANCE

Certificate Number 20180907-EX27656
Report Reference EX27656-20180426
Issue Date 2018-SEPTEMBER-07

Issued to: CNP NM FIRE FIGHTING SYSTEM CO LTD
Factory Area of CNP Changsha Co Ltd
No.45 Xi Chong Road
Quan Tang Street, Changsha ETDZ
Changsha
Hunan 410100 CHINA

This is to certify that representative samples of CENTRIFUGAL FIRE PUMPS, VERTICAL TURBINE
SEE ADDENDUM PAGE

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL448 Standard for for Centrifugal Stationary Pumps for Fire-Protection Service
ULC/ORD C448 Guide for The Investigation of Pumps for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180907-EX27656
Report Reference EX27656-20180426
Issue Date 2018-SEPTEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model Dsg: 250VTP400-28, 250VTP550-26, 300VTP860-43, 350VTP860-43, 350VTP1250-36, 400VTP1250-36.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



Rated Capacity (gpm)	Model Dsg	Rated Net Pressure Range (psi)	Approx Speed (rpm)	Number of Stages
3500	350VTP1250-36	47-62	1480	1
		93-124		2
		140-249		3-4
45-61		1		
4000		90-121		2
		135-243		3-4
		56-74	1600	1
3500		112-148		2
		168-295		3-4
		4000		54-72
107-144				2
161-288				3-4
4000	400VTP1250-36	61-82	1700	1
		122-163		2
		183-245		3
4500		58-79		1
		116-159		2
		174-238		3
5000		229	3	
4000		66-88	1760	1
		133-177		2
		199-265		3
4500		63-86		1
		126-172		2
	189-259	3		
5000	249	3		

Rated Capacity (gpm)	Model Dsg	Rated Net Pressure Range (psi)	Approx Speed (rpm)	Number of Stages
4000	400VTP1250-36	74-98	1840	1
		148-195		2
		222-293		3
4500		70-95		1
		141-190		2
		211-285		3

CONSTRUCTION DETAILS:

The product has been examined and found to comply with the applicable requirements of the Standard for Pumps for Fire-Protection Service, UL 448, and Guide for the Investigation of Pumps for Fire Protection Service, ULC-ORD-C448 in effect as of the date of this Report

USE:

The products covered by this Report are intended for use in accordance with the National Fire Protection Association Standard for the Installation of Stationary Pumps for Fire Protection, NFPA 20 and the manufacturer's design, installation, operation, and maintenance manual.



QXXW.EX27656
Centrifugal Fire Pumps, Vertical Turbine

Page Bottom

Centrifugal Fire Pumps, Vertical Turbine

See General Information for Centrifugal Fire Pumps, Vertical Turbine

CNP NM FIRE FIGHTING SYSTEM CO LTD

EX27656

Factory Area of CNP Changsha Co Ltd

No.45 Xi Chong Road

Quan Tang Street, Changsha ETDZ

Changsha, Hunan 410100 CHINA

Rated Capacity gpm	Model Dsg	Rated Net Pressure Range psi	Approx Speed rpm	Stages	
1250	250VTP400-28	41-51	1480	1	
		82-102		2	
		124-153		3	
		165-305		4-6	
1500		40-49		1760	1
		77-97			2
		115-292	3-6		
1500		58-71	1760	1	
		115-143		2	
		173-214		3	
		230-285		4	
2000		63	1760	1	
	125	2			
	188	3			
	251	4			
2000	250VTP550-26	40-44	1480	1	
		77-88		2	
		116-132		3	
		155-176		4	
		194-264		5-6	
2000		57-66	1760	1	
		113-133		2	
		170-199		3	
		227-266		4	
2500		61	1760	1	
	123	2			
	184	3			

		245		4
2500	300VTP860-43	50-82	1480	1
		100-245		2-3
3000		53-78		1
		105-235		2-3
2500	350VTP860-43	74-118	1760	1
		149-236		2
3000		69-115		1
		139-230		2
3500		73-111		1
		146-222		2
4000		104		1
		207		2

Last Updated on 2018-04-30

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".